

PARTICLE SIZE DISTRIBUTION TEST


BS EN 933-1. 1997

By Washing and Sieving

Sample Number: 1

Classification Type: 4/10mm

4/10mm



BS Test Sieve mm	Percentage Passing %	4/10mm	
		Lower	Upper
63	100		
40	100		
31.5	100		
20	100	100	100
14	100	98	100
10	92	85	100
4	16	0	20
2	2	0	5
1	2		
0.25	1		
0.063	1	0	1.5

Remarks:



Port Salford

Contract No:

PSL23/5089

Client Ref No:

28/06/2023